

# VOC Content Test Certificate

Monday January 5<sup>th</sup>, 2009

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park NSW 2164)

Sample Description: Sikafloor Primer MB solvent free epoxy primer

Date Tested: January 2009

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC)  
Content of Paints and Related Coatings.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</b>	<b>Sikafloor Primer MB</b>
Interior Sealer 65 grams per Litre as VOC content coating	<b>24 grams per Litre as VOC content per coating</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Sikafloor Primer MB</b>
One or two pack performance coating for floors 140 grams per Litre as VOC content coating	<b>24 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0812-37