

VOC Content Test Certificate

Wednesday October 1st, 2008

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park NSW 2164)

Sample Description: Sikabond T53 one-part polyurethane adhesive for timber flooring

Date Tested: September 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Sikabond T53
Wood flooring adhesive 100 grams per Litre as VOC content coating	64 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Sikabond T53
Wood flooring adhesive 100 grams per Litre as VOC content coating	64 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0809-30